## T

Small Electric **Vehicle Use** 

Know what lithium battery powered equipment is kept on site.

Designate a charging and storage area for e-bikes, e-scooters and other equipment (outside of the building, out of direct sunlight, and away from exit doors and combustibles).

Disconnect the chargers when not in use and when the vehicle is fully charged.

Inspect batteries regularly for signs of damage, cracks, or bulges.

Ensure that your sprinkler system can adequately protect the building from a fire from EV devices.

Most lithium-ion batteries can be extinguished by the use of a standard dry chemical extinguisher (Class A-B-C). Review the manufacturer's information to ensure the correct type of extinguisher is being used.

1.800.228.7136

CIRSA.org

